

# **CE** DECLARATION OF CONFORMITY

**NAME OF APPARATUS:** Condensate Drain Pans

**MODEL NUMBER:** 30-220, 31-220, 70-220, 75-220, CP801, CP802(240), CP804(240), CP804HD(240), CP807(240), CP808, CP815(240), CP816, CP817, CP818, CP819, CP820, CP821

**DESCRIPTION OF APPARATUS:** **Condensate Drain Pans**

**Sealed Unit Parts Co., Inc. declares that the above model is in conformity to the following harmonized standards and directives:**

Directive 2006/95/EC		
Normative standard EN 61326-1: 2006	SPECIFICATIONS TO WHICH CONFORMITY IS DECLARED	LEVEL
EN 61000-4-2: 2008 Electrostatic Discharge Test	2,4,6,abd 8 kV Air Discharge 2,4, and 6 kV Contact Discharge	A
EN 61000-4-3: 2008 Radiated Susceptibility Test	4.5 V/M Minimum (4.5 V/M test 900 MHz Cell Phone, 200 Hz, 100% AM	A
EN 55011/EN55022 Radiated Emission	CISPR 16-2-3	B

**Manufacturer:**

Sealed Unit Parts Co.  
P.O. Box 21  
Allenwood, NJ 08720  
USA

Manufacturer's Signature:



Alexander Brodetsky Ph.D  
Sr.Vice President, Engineering

Date: 2/15/2017